



# Lot Services Sketch

PID:	012140350
BU:	121225
WO:	5023522

## CITY OF PRINCE GEORGE

Civic Address: 8351 CANTLE DRIVE

Legal Description: Lot: 30 District Lot: 625 Plan: 14430

Service Type	Diameter (mm)	Material	Invert Elev @ Main (m)	Invert Elev @ Property Line (m)	Invert Elev @ Service End (m)	Distance into Property (m)	Installation Date
Sanitary	100	PVC	742.94	743.27	743.34	2.83	July 2021
Water	19	COPPER	742.91	742.89	743.16	3.02	July 2021
Storm	N/A	-	-	-	-	-	-

Sanitary Service Connection Location Notes	Storm Service Connection Location Notes
Distance from downstream SAN MH #4752: 46.16m	Distance from downstream STM MH #: N/A
Distance to upstream SAN MH #4749: 44.84m	Distance to upstream STM MH #: N/A

Miscellaneous Utilities			
Power	Communications	Cable	Gas
BC Hydro	TELUS	Shaw Cable	FortisBC
Overhead Service	Overhead Service	Overhead Service	Underground Service

Installation By:	City of Prince George	Survey Date:	2021-06-14
Comments:			
Clean Out is ~11.7m from East property line of Lot 30. Curb Stop is ~12.4m from East property line of Lot 30. Services are in centre of Lot 30.			

**NOT TO SCALE** The information contained herein is for internal use only.  
Not to be relied on unless confirmed by site inspection and/or investigation.

