City of Prince George HISTORY SHEET

P.I.D. 026 474 221								
Legal: LOT 6		(6)		D.L.	4377		PLAN BCP20570	
Address: 2434 McTAVISH	ROAD			4				
Sanitary Connection:	SIZE:	100mmø	MATERIAL:	PVC	INV.	654.83m	CONNECTED	
Water Connection:	SIZE:	19mmø	MATERIAL:	COPPER	INV.	655.56m	METER	
Storm Connection:	SIZE	100mmø	MATERIAL	PVC	INV.	655.82m	CONNECTED	
Cash Receipt No's:		WATER		SANITARY			STORM	
CURB FROM PROPERTY LINE	5.0m					PAVEME	NT WIDTH 10.0m	
B.C. HYDRO 75mm DB2				U/G CONNECT	TION	<u> </u>		
B.C. TELEPHONE 50mm DB2	To the second se			U/G CONNECT	TION	_/		
B.C. GAS 42 PROP/P.	<u>.</u>							
Information Sheets: RE	F. DWGS,	L&M ENGINEERIN			DWGS	.(001–305))	
	RB STOP AN OUT		TER SERVICE ORM SERVICE NITARY SERVICE	CE ====================================	CARRE	SERVICE SERVICE OMMUNICATION	ONS	
THE INFOR	MATION	CONTAINED	HEREIN	IS FOR IN	TERN	AL USE	ONLY.	

NOT TO BE RELIED UPON UNLESS CONFIRMED BY THE SITE INSPECTION AND/OR INVESTIGATION

LOT 5

SANITARY, STORM & WATER SERVICE INVERTS	SANITARY	STORM	WATER
1. Distance from San. MH 514602 to connection point is 19.94 toward San. MH 514601		N/A	N/A
1a.Distance from Stm. MH 514603 to connection point is 23.76 toward Stm. MH 514602	N/A	<u> </u>	N/A
2. Main Size at connection point is	200mmø	300mmø	250mmø
3. Invert of main at conn. stub pt is	654.33	655.33	655.07
4. Invert of service end is	654.83	655.82	655.56
5. Cut at P/1 in metars	3.1m	2.1m	2.4m
6. Survey Date AUGUST 20 05 Book Ref. 1253-01-03 by KILBRIDE			
		<u> </u>	
		·	
SANITARY HISTORY:			
WATER HISTORY:			
WATER TROTORY.			
STORM HISTORY:			