



SANITARY, STORM & WATER SERVICE INVERTS	SANITARY	WATER	STORM
1. Distance from San. M.H. <u>5232</u> toward San. M.H. <u>5232</u> to lot service connection point is:	0.00m	N/A	N/A
1a.Distance from Stm. M.H. <u>3790</u> toward Stm. M.H. <u>3790</u> to lot service connection point is:	N/A	N/A	0.00m
2. Main Size at connection point is	525mmØ	200mmØ	600mmØ
3. Invert of service at main conn. stub point is	710.90m	709.80m	710.70m
4. Invert at service end is	710.25m	710.25m	710.25m
5. Cover at property line in meters	2.56m	2.64m	2.56m
6. Survey Date: MAY 2012 Book Ref.:1273-14-04 By: L&M ENGINEERING LTD			

SANITARY HISTORY:

DATE INSTALLED: JULY 2012

INSTALLED BY: SUNLAND UTILITIES LTD

WATER HISTORY:

DATE INSTALLED: JULY 2012

INSTALLED BY: SUNLAND UTILITIES LTD.

STORM HISTORY:

DATE INSTALLED: JULY 2012

INSTALLED BY: SUNLAND UTILITIES LTD.