
City of Prince George HISTORY SHEET

PID: 0293341	10	Scale: 1:1000								
Legal: LOT 16						D.L.:	4045	PLAN:	EPP32590	
Address: 4634 AVTAR	PL									
Sanitary Connection:#		SIZE:	100mmØ	MATERIAL:	PVC	IN	v. 608.55m	CONNE	CTED	
Water Connection:#		SIZE:	19mmØ	MATERIAL:	copper	IN	/. 607.31m	METER		
Storm Connection:#		SIZE	100mmØ	MATERIAL	PVC	IN	v. 608.49m	CONNE	CTED	
Cash Receipt No's:	eceipt No's:		WATER		SANITAF		RY		STORM	
CURB FROM PROPERTY LINE 5m				PAVEM			ENT WIDTH 10m			
B.C. HYDRO	75mm DB2									
B.C. TELEPHONE	100mm DB2									
TERASEN	42 PROP/P.E									
Information Sheets:	REFERENCE	DRAWIN	IGS L&M ENGIN	IEERING LIMITE						
Comments:	CS CUR	B STOP AN OUT	<u> </u>	WATER SERVICE STORM SERVICE SANITARY SERV	E /ICE	=====================================	DRO SERVICE BLE SERVICE LECOMMUNICAST		GAS ELECTRICAL	

THE INFORMATION CONTAINED HEREIN IS FOR INTERNAL USE ONLY. NOT TO BE RELIED UPON UNLESS CONFIRMED BY THE SITE INSPECTION AND/OR INVESTIGATION



SANITARY, STORM & WATER SERVICE INVERTS	SANITARY	WATER	STORM
1. Distance from San. M.H. <u>5246</u> toward San. M.H. <u>5247</u> to lot service connection point is:	103m	N/A	N/A
1a.Distance from Stm. M.H. 3809 toward Stm. M.H. 3810 to lot service connection point is:	N/A	N/A	107m
2. Main Size at connection point is	200mm	200mm	250mm
3. Invert of main at conn. stub point is	607.92m	607.25m	607.82m
4. Invert at service end is	608.68m	607.33m	608.68m
5. Cut at property line in meters	2.57m	3.84m	2.62m
6. Survey Date: OCT 2012 Book Ref.:1256-04-04 By:ALLNORTH			
CANITARY LICTORY			
SANITARY HISTORY:			
Installed By: Klein and Sons Construction			
WATER HISTORY:			
Installed By: Klein and Sons Construction			
Installed by. Rielli and Sons Construction			
STORM HISTORY:			
Installed By: Klein and Sons Construction			