



CITY OF  
PRINCE GEORGE

Civic Address: 2728 & 2730 MOYIE ST

Legal Description: Lot: 1 District Lot: 933 Plan: EPP103349

Lot Services Sketch

PID:

031508987

Service Type	Diameter (mm)	Material	Invert Elev @ Main (m)	Invert Elev @ Property Line (m)	Invert Elev @ Service End (m)	Distance into Property (m)	Installation Date
Sanitary	100	PVC	-	582.85	582.96	2.10	September 2018
Water	19	COPPER	-	582.62	-	-	December 1954
Storm	N/A	-	-	-	-	-	-

Sanitary Service Connection Location Notes	Storm Service Connection Location Notes
Distance from downstream SAN MH #3529: 31.35m	Distance from downstream STM MH #: N/A
Distance to upstream SAN MH #3870: 27.71m	Distance to upstream STM MH #: N/A

Miscellaneous Utilities			
Power	Communications	Cable	Gas
BC Hydro	TELUS	Shaw Cable	FortisBC
Overhead Service	Overhead Service	Overhead Service	Underground Service

Installation By:	City of Prince George	Draft Date:	2022-10-25	Survey Date:	-
------------------	-----------------------	-------------	------------	--------------	---

Comments:
Sanitary Service is ~7.3m North from the South West corner of Lot 1. Curb Stop is ~8.3m North from the South West corner of Lot 1.
MU#: 101895. WO#: 96618.

**NOT TO SCALE** The information contained herein is for internal use only.  
Not to be relied on unless confirmed by site inspection and/or investigation.

