## **Lot Services Sketch**

PID:

031524541



PRINCE GEORGE

Civic Address: 2130, 2140 QUINN ST

Legal Description: Lot: 2 District Lot: 936 Plan: EPP108557

Service Type	Diameter (mm)	Material	Invert Elev @ Main (m)	Invert Elev @ Property Line (m)	Invert Elev @ Service End (m)	Distance into Property (m)	Installation Date
Sanitary	100	AC	-	-	-	2.38	December 1964
Water (W1)	25	COPPER	-	-	-	-	December 1964
Water (W2)	25	COPPER	-	-	-	-	December 1964
Storm	300	VIT CLAY	-	-	-	-	December 1966

Sanitary Service Connection Location Notes	Storm Service Connection Location Notes		
Distance from downstream SAN MH #3361: 40.78m	Distance from downstream STM MH #2691: 0.000m		
Distance to upstream SAN MH #3359: 50.32m	Distance to upstream STM MH #2691: 0.000m		

Miscellaneous Utilities								
Power	Communications	Cable	Gas					
BC Hydro	TELUS	Shaw Cable	FortisBC					
Overhead Service	Overhead Service	Overhead Service	Underground Service					

Installation By: City of Prince George Survey Date: -

## Comments:

Sanitary Service is on the south property line of Lot 2. W1 is  $\sim$ 0.6m from the South West corner of Lot 2.

Storm Service is ~20.3m from the South West corner of Lot 2. W2 is ~31.0m from the South West corner of Lot 2.

## NOT TO SCALE The information contained herein is for internal use only. Not to be relied on unless confirmed by site inspection and/or investigation.

